Commonwealth of Kentucky Division for Air Quality

PERMIT APPLICATION SUMMARY FORM

Completed by: Ben Markin

GENERAL INFORMATION:		
Name:	Kentucky State Reformatory.	
Address:	3001 West Highway 146, LaGrange, Kentucky 40032	
Date application received:	October 03, 2001	
SIC/Source description:	Construction/Operation of Indirect Heat Exchangers	
AFS #:	21-185-00012	
Application log number:	54193	
Permit number:	V-02-002	
APPLICATION TYPE/PERMIT ACTIVITY	:	
[x] Initial issuance	[] General permit	
[] Permit modification	[]Conditional major	
Administrative	[x] Title V	
Minor	[x] Synthetic minor	
Significant	[] Operating	
[] Permit renewal	[x] Construction/operating	
COMPLIANCE SUMMARY:		
[] Source is out of compliance	•	
[x] Compliance certification sig	gned	
APPLICABLE REQUIREMENTS LIST:		
[x] NSR	[] NSPS [x] SIP	
[] PSD	[] NESHAPS [] Other	
[] Netted out of PSD/NSR	[] Not major modification per 401 KAR 51:017, 1(23)(b) or 51:052,1(14)(b)	
MISCELLANEOUS:		
[] Acid rain source		
[] Source subject to 112(r)		
[] Source applied for federally	y enforceable emissions cap	
[] Source provided terms for	alternative operating scenarios	
[] Source subject to a MACT	ſ standard	
[] Source requested case-by-	case 112(g) or (j) determination	
[] Application proposes new	control technology	
[x] Certified by responsible off	icial	
[x] Diagrams or drawings inclu		
[] Confidential business inform	mation (CBI) submitted in application	
[] Pollution Prevention Measu	ıres	
[] Area is non-attainment (list	pollutants):	

EMISSIONS SUMMARY:

Pollutant	Actual (tpy)	Potential (tpy)
PM	11.04	19.98
PM10	10.91	10.95
SO_2	1.61	8.92
NOx	144.83	150.11
СО	117.16	119.5
VOC	13.87	16.81
HAPs	1.97	2.95

SOURCE PROCESS DESCRIPTION:

A construction/operating permit application was received from Kentucky State Reformatory on October 03, 2001 and was considered complete on November 20, 2001. The applicant proposes to construct/operate two natural-gas fired indirect heat exchangers with backup #2 fuel oil rated at 70 mm BTU/hr each, operate three existing permitted boilers and disconnect one that has been out of service for more than a year at their source in LaGrange, Kentucky. The source is taking self- imposed limits to preclude the applicability of Prevention of Significant Deterioration (PSD)[Regulation 401 KAR 51:017] review.

.

EMISSION AND OPERATING CAPS DESCRIPTION:

Source-wide usage of #2 fuel oil for all boilers and diesel generators shall not equal or exceed 231,845 gallons per year. Allowable hours of operation for each boiler using #2 fuel oil shall not exceed 96 hours and 52 hours for each generator per each consecutive twelve (12) month rolling total.

OPERATIONAL FLEXIBILITY:

None